

RESOLUTION NO. 400

A RESOLUTION OF THE BOARD OF COMMISSIONERS OF
BIRCH BAY WATER DISTRICT NO. 8, WHATCOM COUNTY,
WASHINGTON, RELATING TO AND PROVIDING FOR ONE
TIME WATER COURTESY TURNOFFS.

BE IT RESOLVED by the Board of Commissioners of Birch Bay Water
District No. 8, Whatcom County, Washington, as follows:

Section 1: Every premises shall have a shut-off valve installed
between the water meter and the first connection or branch beyond
the meter. This valve shall stop water flow for the entire prem-
ises, and shall be in the control of the owner or occupant. The
shut-off valve must be a brass hand wheel operated gate valve.
Stop and waste type valves will not be permitted as they are a
potential source of contamination. Existing services without such
a shut-off valve will be allowed one shut-off and turn-on without
fee for installation of such a valve. After any shut-off, water
service will not be restored until the required shut-off valve is
installed and inspected by the district.

Section 2: This resolution shall become effective immediately and
shall apply to any courtesy turn-offs made hereafter.

Section 3: All resolution or parts of resolution that conflict here-
with are hereby repealed.

ADOPTED at a regular meeting of the Board of Water Commissioners of
Birch Bay Water District No. 8, held this 9th day of February, 1984.

Francis D. Lischer
COMMISSIONER

Harold O. Johnson
COMMISSIONER

COMMISSIONER

THIS IS TO CERTIFY that the above is a true and correct copy of
Resolution No. 400 of the Board of Water Commissioners of Birch Bay
Water District No. 8, Whatcom County, Washington, adopted at the
regular meeting thereof on the 9th day of February, 1984.

Harold O. Johnson
SECRETARY